



ELEVATION



SIDE VIEW



PLAN

DISCRIPTION	MARK	SIZES
INLET PIPE CONNECTION	A	4" X 1 No
OUT LET PIPE CONNECTION	B	4" X 1 No.
DRAIN & OVERFLOW CONNECTION	C	2" EACH
MAKE UP AND QUICKFILL CONNECTION	D	1.5" EACH
LENGTH OF COOLING TOWER		1500
WIDTH OF COOLING TOWER		1500
FAN DIA AND NOS.	P	#1200 X 1 No.

DELTA COOLING TOWERS P. LTD.

SITE:-

DES.	DRN.	CHRD.	APRD.	SCALE NOT TO SCALE	JOB NO.	REV-0

G.A OF DRG. OF COOLING
TOWER MODEL NO.6040/6050
SERIES- DFC 60

- NOTES:-**
- 1 ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE STATED
 - 2 COOLING TOWER WILL BE ASSEMBLED ON BRICK PILLER
 - 3 MAKEUP AND QUICKFILL CONNECTION TO BE PROVIDED WITH THREAD CONNECTIONS AS PER IS -544-1955
 - 4 INLET AND OUTLET CONNECTION TO BE PROVIDED WITH FLANGE CONNECTIONS AS PER TABLE "E" OF IS.
 5. BRICK PILLER 675 X 675 X 600 HEIGHT