



K	F	O	I	L	E	N	M	P
6428	6180	1545	515	8974	8624	2156	539	2100

DISCUSSION	MARK	SIZES
INLET PIPE CONNECTION	A	200 x 4 NOS
OUT LET PIPE CONNECTION	B	200 x 4 NOS.
DRAIN & OVERFLOW CONNECTION	C	50 EACH
MAKE UP AND QUICKFILL CONNECTION	D	40 EACH
LENGTH OF COOLING TOWER	E	8624
WIDTH OF COOLING TOWER	F	6180
FAN DIA AND NOS.	P	ø2100 x 4 Nos.

- NOTES:-**
- ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE STATED.
 - COOLING TOWER WILL BE ASSEMBLED ON ISA FRAME FIXED ON RCC FILLER THE FRAME IS UNDER PURCHASERS SCOPE.
 - MAKEUP AND QUICKFILL CONNECTION TO BE PROVIDED WITH THREAD CONNECTIONS AS PER IS-544-1955.
 - INLET & OUTLET CONNECTION TO BE PROVIDED WITHOUT FLANGE.
 - RCC BASIN AND RCC PILLERS 250x250x700 HEIGHT AND ø12x 150 LONG BOLTS ARE UNDER PURCHASER SCOPE.
 - ø10 mm HOLE AT THE DISTANCE OF 5" ON THE PERIPHERAL OF ISA OF THE BASE FRAME SHALL BE PROVIDED BY PURCHASER.
 - LOCATION OF OUTLET CONNECTION ACCORDING TO SITE REQUIREMENT.
 - ø12x150 LONG BOLTS SHALL BE GROUTED IN THE CENTRE OF OUTER COLUMNS AS SHOWN IN THE DRAWING.
 - 9. ALL ISA (ANGLES) ON PERIPHERAL WILL FACE OUTSIDE ie IT**
- DELTA COOLING TOWERS P. LTD.**
- SITE:-
- G.A OF DRG. OF COOLING TOWER MODEL NO. 61K1 SERIES- DFC 60
- SCALE: NOT TO SCALE
- APPD: [Signature]
- DRN: [Signature]
- CHKD: [Signature]
- REV-0