


ELEVATION OF PILLER WITHOUT BOLT OF MKD - "R" (QTY- 14 NOS.)

700

BOLT/TOR 12mmX150mm LONG.







ELEVATION OF PILLER WITHOUT BOLT OF MKD - "S" (QTY-6 NO.)

Notes:-

- All dimensions are in milimeters.
- 3. Makeup and quickfill connection shall be provided with thread connections as per is-544-1955. 2. Cooling tower will be assembled on ISA-50x50x6 frame fixed on RCC pillar the frame is under purchasers scope unless othervise stated
- 4 Inlet & outlet connection shall be provided without flange.
- 6 Ċī RCC basin and RCC pillers 250x250x700 ht. And Ø12 x 150 long bolts/tor are under purchaser scope.
- .7 Location of outlet connection will be as per the site requirement.

10 mm hole at the distance of 125mm on the peripheral of ISA of the base frame shall be provided by purchaser

- \$12x150 long bolts/tor shall be grouted in the centre of outer columns as shown in the drawing.
- All pictures shown are for illustration purpose only and may differ from the actual cooling tower model

9 ∞

1									
	ō.	Ø2100 X 4 Nos	P				OS.	FAN DIA AND NOS.	FAN D
_		6194	F			WER	LING TO	WIDTH OF COOLING TOWER	WIDTI
_		8610	E)WER	OLING TO	LENGTH OF COOLING TOWER	LENG
		25 X 2 NOS	D		CTION	MAKEUP AND QUICKFILL CONNECTION	QUICKFIL	UP AND (MAKE
_		50 X 2 NOS.	C		Ž	DRAIN & OVERFLOW CONNECTION	FLOW CC	& OVER	DRAIN
_	S	200 X 4 NOS	B .			2	ONNECTI	OUTLET PIPE CONNECTION	OUTL
	S.	200 X 4 NOS.	A :			V	INECTION	INLET PIPE CONNECTION	INLET
	S	SIZES	MARK	M		TON	DESCRIPTION	I	
'									
	2100	516 2152 2065	2152	516	538	8860	6444	6194	8610
_	F	0	Z	_	M	L	K	٠.	Į.

Base Frame

OPERATING WEIGHT (KG.)

1680

DesignOnContract.com

REV: 12/2017

NOT TO SCALE / DO NOT SCALE DRAWING	JOB NO.:
G.A OF DRG. OF COOLING TOWER MODEL NO. 61K1 SERIES - DFC 60	TOWER MODEL NO. 61K1 FC 60
COMPANY:	
Delta Cooling Towers P. Ltd	ers P. Ltd
(PH - 011-27495801/02/03) EMAIL- mail@delta.cool	mail@delta.cool
SITE:	